EFFECT OF TRANSFORMER LEAKAGE INDUCTANCE ON CAPACITIVE INPUT FILTERS


James P. O'Loughlin Steven L. West Air Force Weapons Laboratory/ARAY Kirtland AFB, NM 87117

Summary

The effect of series inductance on the performance of the capacitive input power filter has been analyzed by computer and is presented in a set of design curves. The results show that the normally encountered leakage inductance of a transformer has a pronounced effect on reducing the peak and RMS currents in the capacitive input filter circuit. This reduction shows the capacitive input filter to be much more practical than previously believed, especially for high power applications.

Introduction

The detailed analysis of capacitive input filters including inductive reactance was first published in the doctoral thesis of R. L. Freeman in 1934^{1} . The equations are awkward and calculations so time consuming they are not usable in practical design work nor were they ever reduced to design tables or charts. A simplified analysis neglecting the reactance was done by O. H. Schade and published as the well-known "Schade Curves" in 1943.² Schades Curves give misleading results in most practical cases; specifically the rectifier peak and RMS currents given are much higher than those actually encountered. In this paper computer generated curves are given which show that when the normally encountered transformer leakage inductance is accounted for the capacitive input filter is comparable to the choke input filter in terms of component utilization. In reality the capacitive input filter is much more practical and competative at high power levels than was generally accepted. The circuit of a full wave single phase capacitive input filter (CIF) is shown in Fig. 1 and includes series inductance and resistance. Analysis of the circuit is more trouble than one would expect from such a simple schematic. The problem is one of lengthy awkward equations not one of mathematical difficulty. The current flows for only a portion of each cycle and the equations for the starting and ending angles of conduction are transendental. The calculation of the parameters of interest. i.e. peak, RMS and average currents and voltages are very tedious and time consuming, and is the reason that before the coming of computers only the simplified case of zero inductance was published by 0. H. Schade in 1943. In practice the zero inductance case is seldom realized; in fact any capacitive input rectifier fed by a transformer, of comparable power rating, will be dominated by the transformer leakage inductance. The leakage inductance strongly influences the circuit because of the high harmonic content of the current waveform and the fact that the reactance of the leakage is proportional to frequency. Only a few percent reactance at the fundamental frequency, which is normally inherent in a transformer, typically reduces the RMS current by a large factor compared to the zero inductance case. Historically CIF's have been avoided in high power circuits becaue it was wrongly assumed that the zero inductance curves were a reasonable approximation to the case of a few percent reactance. Consequently the RMS currents predicted gave a transformer kVA rating much higher than that actually required. This apparently poor transformer utilization factor would thus lead to the choice for a choke input filter. Furthermore the zero reactance curves are always on the conservative side, that is they always predict RMS and peak currents higher than those in a real circuit which contains a small amount of inductance. Therefore, any time a circuit was designed on the basis of the zero reactance curves, it never gave any trouble because it was actually over designed Since few problems developed from over-stressed components the practice of assuming the zero reactance curves were a good approximation was not questioned.



CAPACITIVE INPUT FILTER (CIF) RECTIFIER Fig. 1

Method of Analysis

The circuit upon which the analysis is based is that shown in Fig. 1. Following the work of Schade, the basic parameter taken as the independent variable and abscissa for the curves is ωRC. A computer program was written to calculate the peak, average and RMS currents and the peak to peak voltage ripple and average voltage as a function of ωRC over the range of .1 to 1000. These computations were made for various series resistance (Rs) and reactances (Xs) expressed as percentages of the load resistance (R). The reactance Xs is taken at the line frequency ω . The results are plotted in Figs. 2 and 3 for series resistance values of 1% and 7% and reactance values of 0%, 1%, 3%, 7% and 10%. Space does not permit more extensive plots but the important point to be made is the effect of the reactance on the peak and the RMS currents and this is clearly shown in Figs. 2 and 3. For example at ωRC = 100, Xs = 0.0 and Rs = 1% the RMS current is 2.3 times the d.c. current; and with the same condition except Xs = 3%, the RMS current drops to 1.65 times the d.c.. The corresponding change in peak current is 6.64 times the d.c. at Xs = 0% to 3.51times at Xs = 3%.


In CIF circuits using transformers the effect increases with the power level of the circuit due to transformer characteristics. In general the per unit (or percent) resistance of a transformer decreases and

including suggestions for reducing	completing and reviewing the collect this burden, to Washington Headqu uld be aware that notwithstanding ar DMB control number.	arters Services, Directorate for Info	ormation Operations and Reports	s, 1215 Jefferson Davis	Highway, Suite 1204, Arlington	
1. REPORT DATE JUN 1981		2. REPORT TYPE N/A		3. DATES COVE	ERED	
4. TITLE AND SUBTITLE				5a. CONTRACT NUMBER		
Effect Of Transformer Leakage Inductance On Capacitive			e Input Filters	5b. GRANT NUMBER		
				5c. PROGRAM I	ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER		
					5e. TASK NUMBER	
				5f. WORK UNIT NUMBER		
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Air Force Weapons Laboratory/ARAY Kirtland AFB, NM 87117				8. PERFORMING ORGANIZATION REPORT NUMBER		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)		
				11. SPONSOR/M NUMBER(S)	IONITOR'S REPORT	
12. DISTRIBUTION/AVAIL Approved for publ	LABILITY STATEMENT ic release, distributi	on unlimited				
Abstracts of the 20	OTES 71. 2013 IEEE Pulso 13 IEEE Internation 1.S. Government or 1	nal Conference on l	Plasma Science. H	-	· · · · · · · · · · · · · · · · · · ·	
14. ABSTRACT						
15. SUBJECT TERMS						
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF	18. NUMBER	19a. NAME OF	
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified	- ABSTRACT SAR	OF PAGES 4	RESPONSIBLE PERSON	


Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and

Report Documentation Page

Form Approved OMB No. 0704-0188



Capacitive Input Filter Characteristics Normalized Peak Current (\hat{I}/I_{DC}), RMS Current (I_{RMS}/I_{DC}) and DC Voltage (E_{DC}/\hat{E}) vs $\omega RC \text{ for 1% } (R_S/R_L) \text{ and } X_S/R_L \text{ of 0%, 1%, 3%, 7% and 10\%}$




Capacitive Input Filter Characteristics Normalized Peak Current (\hat{I}/I_{DC}), RMS Current (I_{RMS}/I_{DC}) and DC Voltage (E_{DC}/\hat{E}) vs $_{\omega RC}$ for 7% (R_{S}/R_{L}) and X_{S}/R_{L} of 0%, 1%, 3%, 7% and 10%

the per unit reactance increases as the volt-amp rating of the transformer increases. An approximate emperical pair of equations for this behavior is:

(1)
$$%R = .75 \times VA^{-.292} \times f^{-.219} \times 100$$


(2)
$$%X = .000875 \times VA^{.161} \times f^{.438} \times 100$$

Equations (1) and (2) are plotted in Fig. 4, normalized for 60 Hz. Note that the P.U. R and X in equations (1) and (2) and Fig. 4 are on the base of the transformer impedance not the rectified load resistance. As the power level increases the increase in reactance tends to improve the transformer utilization in a CIF but it decreases the utilization in a choke input circuit because of the tendency to drag out the rectifier commutation 3 .



Transformer Utilization Comparison

Based on the assumption of zero reactance one finds the transformer utilization of CIF to be much lower than a choke input filter. However, in reality this is not true, the utilization is typically about the same. To illustrate this the same 50 kVA transformer with 1.3% R and 3.0% X was analyzed in a choke input and capacitive input circuit. The circuits are shown in Fig. 5. The analysis was carried out by a computer program which adjusted the load resistance until the transformer was operating at rated kVA. The same value of capacitance, .46 farads, was used in both circuits, but the choke input circuit of course required a choke. The value used was minimum (critical) inductance of 180 microhenrys which has an equivalent kVA of 5.4. The program calculated current waveforms and their harmonic content as well as the voltages and currents. The results are tabulated in Figs. 6 and 7, and show that the utilization on a KW per kVA basis is higher for CIF. The most significant difference occured in the harmonic content of the line current, being higher for the CIF.






Fig. 7 Comparative CIF and IIF Data

PARAMETER	CIF	IIF
Transformer kVA Inductor kVA RMS Line Voltage (V) RMS Line Current (A) % 3rd Line Current % 5th Line Current % 7th Line Current % 9th Line Current	50 0 100 500 76.1 41.5 14.2 7.9	50 5.4 100 500 28.0 11.4 6.7 4.7
% 11th Line Current	6.7	3.5
% 13th Line Current	3.5	2.8
% 15th Line Current	3.3	2.3
D.C. Voltage (V)	128.3	87.8
D.C. Current (A)	273.5	398.1
Power Out (kW)	35.1	35.0
Utilization kW/kVA	.702	.632
% P-P Ripple	2.52	2.84

Conclusion

The leakage reactance normally encountered in a power transformer has a significant effect on the performance of CIF circuits. When this effect is accounted for, the utilization factor (KW per kVA) is about as good in the CIF circuit as if it is in the choke input rectifier circuit. This is particularly true in the higher power cases.

References

- R. L. Freeman, Analysis of Rectifier-Filter Circuits, Doctoral Thesis, Stanford Univ. Library, 1934.
- (2) O. H. Schade, Analysis of Rectifier Operation, Proceedings of the IRE, July 1943, pp. 341-361.
- (3) R. L. Witzke, J. V. Kresser and J. K. Dellard, Influence of A-C Reactance on Voltage Regulation of 6-Phase Rectifiers, Transactions of AIEE, July 1953, pp. 244-252.